



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: (352) 343-9473
www.lakegovernment.com

ADDENDUM NO. 3

Date: March 6, 2015

Invitation to Bid (ITB) 15-0210

PROVIDE AND INSTALL A VEHICLE CANOPY AT FIRE STATION 90/104

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid from being considered for award.

This addendum DOES NOT change the date for receipt of bids or proposals.

The following additional questions/answers are provided via this addendum:

Question 13: What type ss roof 24" double-lok or 16" battenlok?

Answer 13: The specification is for standing seam with Kynar finish, minimum 24 gauge, installed per manufacturer's specifications and per code.

Question 14: Is exposure c or b required?

Answer 14: Contractor will need to determine exposure using provided documentation.

Question 15: What is roof Pitch?

Answer 15: No roof pitch was specified. Must meet minimum requirements of roofing material installed and must meet minimum height requirement as indicated on drawing.

Acknowledgement of Addendum:

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _ _____